

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: April 9, 2025
Sample ID: 25009
Date Analyzed: 4/2/25
WO Number: 250327009

Customer:	Greater Johnstown School District	Collection Date: 3/27/25
Address:	1 Sir Bills Circle, Suite 101, Johnstown, New York 12095	Collection Time: See Chart
Sample Location:	Knox Middle School	Collected by: Angelo E. Finateri
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp:

Sample #	<u>Knox Middle School Sample Point</u>	<u>Collection Time</u>	<u>Date</u>	<u>Test Result</u> (µg/l)	<u>MCL</u> (µg/l)	<u>Qualifier</u>	<u>Method</u>
113	K-0-006-DF Ground floor boys fountain	5:48:13 AM	3/27/2025	ND	5.0		SM3113B
****	K-0-007-BB Cafeteria white fountain left bubbler	****	3/27/2025	No Flush, not working.	5.0		SM3113B
****	K-0-008-BB Cafeteria white fountain right bubbler	****	3/27/2025	No Flush, not working.	5.0		SM3113B
****	K-0-009-BF Cafeteria white fountain bottle filler	****	3/27/2025	No Flush, not working.	5.0		SM3113B
129	K-0-011-SP Kitchen dish machine sprayer	5:39:58 AM	3/27/2025	1.7	5.0		SM3113B
111	K-0-12-SF Kitchen dish machine faucet	5:39:29 AM	3/27/2025	4.1	5.0		SM3113B
110	K-0-13-SF Right side of kitchen 3 bay	5:41:34 AM	3/27/2025	ND	5.0		SM3113B
112	K-0-014-SF Left side of kitchen 3 bay	5:40:47 AM	3/27/2025	4.0	5.0		SM3113B
99	K-0-016-SF Kitchen restroom	5:38:19 AM	3/27/2025	1.3	5.0		SM3113B
153	K-0-024-SF Boys coach bathroom sink	5:45:12 AM	3/27/2025	2.7	5.0		SM3113B
82	K-0-031-IC Weight room ice machine	5:44:42 AM	3/27/2025	ND	5.0		SM3113B
109	K-0-039-DF Girls ground floor fountain	5:46:54 AM	3/27/2025	ND	5.0		SM3113B
119	K-1-042-SF Nurse foot controlled sink	5:50:55 AM	3/27/2025	3.0	5.0		SM3113B
93	K-1-043-SF Nurse exam room sink, plastic knobs	5:51:38 AM	3/27/2025	3.2	5.0		SM3113B
107	K-1-044-SF Nurse bathroom sink	5:52:27 AM	3/27/2025	2.7	5.0		SM3113B
100	K-1-052-DF Boys fountain first floor	5:53:27 AM	3/27/2025	ND	5.0		SM3113B
78	K-1-058-SF Principal bathroom	5:55:22 AM	3/27/2025	4.1	5.0		SM3113B
98	K-1-059-SF Music room sink	5:57:36 AM	3/27/2025	5.7	5.0	X	SM3113B
95	K-1-060-SF Home Ec first faucet on the left.	6:00:10 AM	3/27/2025	ND	5.0		SM3113B
103	K-1-061-SF Home Ec second clockwise around room	6:01:43 AM	3/27/2025	ND	5.0		SM3113B
106	K-1-062-SF Home Ec third clockwise around room	6:01:46 AM	3/27/2025	ND	5.0		SM3113B
84	K-1-063-SF Home Ec fourth clockwise around room	6:03:04 AM	3/27/2025	ND	5.0		SM3113B
97	K-1-064-SF Guidance bathroom	6:05:28 AM	3/27/2025	3.7	5.0		SM3113B
90	K-1-065-DF Girls first floor fountain	6:06:50 AM	3/27/2025	ND	5.0		SM3113B

[illegible]

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: April 9, 2025
Sample ID: 25009
Date Analyzed: 4/2/25
WO Number: 250327009

Customer: Greater Johnstown School District
Address: 1 Sir Bills Circle, Suite 101, Johnstown, New York 12095
Sample Location: Knox Middle School
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes

Collection Date: 3/27/25
Collection Time: See Chart
Collected by: Angelo E. Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp:

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

**Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:*

- 1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).*
- 2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.*

Qualifiers Key:

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

< = Less than
> = Greater than
≈ = Approximately
NP = Not Provided
mg/l = milligrams per liter = ppm
ppm = parts per million
µg/l = micrograms per liter = ppb
ppb = parts per billion
gpg = grains per gallon
MCL = Maximum Contaminant Level
SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350