

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: March 27, 2025
Sample ID: 25007
Date Analyzed: 3/20/25
WO Number: 250313007

Customer:	Greater Johnstown School District	Collection Date: 3/13/25
Address:	1 Sir Bill Circle, Johnstown, New York 12095	Collection Time: See Chart
Sample Location:	Pleasant Avenue Elementary School	Collected by: Angelo E. Finateri
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp: Ambient

Sample #	Pleasant Avenue School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
124	P-0-002-SF Kitchen faucet	5:08:22 AM	3/13/25	9.7	5.0	X	EPA-200.8 REV.5.4
121	P-0-003-SP Kitchen sprayer 2	5:08:58 AM	3/13/25	4.4	5.0		EPA-200.8 REV.5.4
116	P-0-004-SF Kitchen faucet 3	5:10:20 AM	3/13/25	16.8	5.0	X	EPA-200.8 REV.5.4
120	P-0-005-SP Kitchen sprayer 4	5:11:05 AM	3/13/25	6.4	5.0	X	EPA-200.8 REV.5.4
39	P-0-009-DF Cafeteria fountain	5:12:14 AM	3/13/25	109.0	5.0	X	EPA-200.8 REV.5.4
63	P-0-010-DF cafeteria hall fountain	5:13:07 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
126	P-0-011-DF Gym fountain	5:16:12 AM	3/13/25	3.2	5.0		EPA-200.8 REV.5.4
47	P-0-012-SF Gym girls sink	5:15:10 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
62	P-0-014-SF Gym boys sink	5:14:23 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
51	P-0-016-SF Girls front hall left sink	5:17:01 AM	3/13/25	7.9	5.0	X	EPA-200.8 REV.5.4
45	P-0-017-SF Girls front hall right sink	5:17:26 AM	3/13/25	2.7	5.0		EPA-200.8 REV.5.4
70	P-0-019-SF Boys front hall left sink	5:18:10 AM	3/13/25	1.9	5.0		EPA-200.8 REV.5.4
59	P-0-020-SF Boys front hall right sink	5:18:43 AM	3/13/25	3.4	5.0		EPA-200.8 REV.5.4
50	P-0-021-SF Room 30 sink	5:20:09 AM	3/13/25	9.5	5.0	X	EPA-200.8 REV.5.4
69	P-0-022-BB Room 30 bubbler	5:19:45 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
68	P-0-023-SF Room 29 sink	5:22:11 AM	3/13/25	10.1	5.0	X	EPA-200.8 REV.5.4
66	P-0-024-SF Room 28 sink	5:23:51 AM	3/13/25	11.0	5.0	X	EPA-200.8 REV.5.4
57	P-0-025-BB Room 28 bubbler	5:23:26 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
49	P-0-026-SF Room 27 sink	5:25:42 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
52	P-0-027-SF Room 27 sink 2	5:26:20 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
34	P-0-028-SF Room 27 sink 3	5:27:25 AM	3/13/25	11.9	5.0	X	EPA-200.8 REV.5.4
58	P-0-029-BB Room 27 bubbler	5:27:02 AM	3/13/25	1.1	5.0		EPA-200.8 REV.5.4
44	P-0-030-SF Room 25 faucet	5:29:15 AM	3/13/25	5.5	5.0	X	EPA-200.8 REV.5.4
54	P-0-031-BB Room 25 bubbler	5:28:48 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: March 27, 2025
Sample ID: 25007
Date Analyzed: 3/20/25
WO Number: 250313007

Customer:	Greater Johnstown School District	Collection Date: 3/13/25
Address:	1 Sir Bill Circle, Johnstown, New York 12095	Collection Time: See Chart
Sample Location:	Pleasant Avenue Elementary School	Collected by: Angelo E. Finateri
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp: Ambient

Sample #	Pleasant Avenue School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifiers	Method
33	P-0-033-BB Room 26 bubbler	5:31:13 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
35	P-0-034-SF Room 26 sink	5:31:14 AM	3/13/25	3.1	5.0		EPA-200.8 REV.5.4
56	P-0-035-SF Back hall staff bathroom	5:32:12 AM	3/13/25	1.2	5.0		EPA-200.8 REV.5.4
41	P-0-036-SF Girls back hall bathroom	5:35:04 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
61	P-0-037-DF Back hall fountain left	5:36:14 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
60	P-0-038-DF Back hall fountain right	5:35:48 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
37	P-0-039-SF Boys back hall bathroom	5:37:35 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
Not Sampled	P-0-042-SF Room 23 sink	Not Sampled	3/13/25	****	5.0		EPA-200.8 REV.5.4
Not Sampled	P-0-043-BB room 23 bubbler	Not Sampled	3/13/25	****	5.0		EPA-200.8 REV.5.4
Not Sampled	P-0-044-SF Room 22 sink	Not Sampled	3/13/25	****	5.0		EPA-200.8 REV.5.4
Not Sampled	P-0-045-BB Room 22 bubbler	Not Sampled	3/13/25	****	5.0		EPA-200.8 REV.5.4
36	P-0-046-SF Room 21 sink	6:02:10 AM	3/13/25	3.7	5.0		EPA-200.8 REV.5.4
53	P-0-047-BB Room 21 bubbler	6:02:26 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
40	P-0-048-SF Room 20 sink	6:04:09 AM	3/13/25	6.6	5.0	X	EPA-200.8 REV.5.4
48	P-0-049-BB Room 20 bubbler	6:03:45 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
43	P-0-050-SF Room 19 sink	6:05:52 AM	3/13/25	4.0	5.0		EPA-200.8 REV.5.4
32	P-0-051-BB Room 19 bubbler	6:05:28 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
29	P-0-052-SF Room 18 sink	6:08:08 AM	3/13/25	6.0	5.0	X	EPA-200.8 REV.5.4
42	P-0-053-BB Room 18 bubbler	6:07:45 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
55	P-0-054-SF Room 17 sink	6:11:11 AM	3/13/25	10.6	5.0	X	EPA-200.8 REV.5.4
72	P-0-055-BB Room 17 bubbler	6:11:00 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4
16	P-0-056-SF Back hall handicap restroom	6:12:32 AM	3/13/25	1.2	5.0		EPA-200.8 REV.5.4
65	P-0-059-SF Room 14 sink	6:14:36 AM	3/13/25	5.3	5.0	X	EPA-200.8 REV.5.4
64	P-0-060-BB Room 14 bubbler	6:14:16 AM	3/13/25	ND	5.0		EPA-200.8 REV.5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: March 27, 2025
Sample ID: 25007
Date Analyzed: 3/20/25
WO Number: 250313007

<i>Customer:</i> Greater Johnstown School District	<i>Collection Date:</i> 3/13/25
<i>Address:</i> 1 Sir Bill Circle, Johnstown, New York 12095	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Pleasant Avenue Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i> Ambient

Sample #	Pleasant Avenue School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifiers	Method
17	P-0-061-SF Room 14 bathroom sink	6:15:28 AM	3/13/25	2.2	5µg/l		EPA-200.8 REV.5.4
15	P-0-062-SF Room 15 sink	6:16:38 AM	3/13/25	8.4	5µg/l	X	EPA-200.8 REV.5.4
18	P-0-063-BB Room 15 bubbler	6:17:12 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
27	P-0-064-SF Room 12 bathroom sink	6:18:47 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
19	P-0-065-SF Room 12 sink	6:20:01 AM	3/13/25	5.9	5µg/l	X	EPA-200.8 REV.5.4
25	P-0-066-BB Room 12 bubbler	6:19:28 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
20	P-0-067-SF Room 11 sink	6:22:21 AM	3/13/25	7.8	5µg/l	X	EPA-200.8 REV.5.4
21	P-0-068-BB Room 11 bubbler	6:21:56 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
24	P-0-069-SF Room 10 bathroom sink	6:23:54 AM	3/13/25	2.0	5µg/l		EPA-200.8 REV.5.4
28	P-0-071-SF Room 10 sink	6:26:07 AM	3/13/25	14.9	5µg/l	X	EPA-200.8 REV.5.4
22	P-0-072-BB Room 10 bubbler	6:25:42 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
23	P-0-073-SF Room 9 sink	6:28:01 AM	3/13/25	6.7	5µg/l	X	EPA-200.8 REV.5.4
4	P-0-074-BB Room 9 bubbler	6:27:40 AM	3/13/25	2.2	5µg/l		EPA-200.8 REV.5.4
6	P-0-075-SF Faculty room sink	6:29:28 AM	3/13/25	4.0	5µg/l		EPA-200.8 REV.5.4
8	P-0-077-SF Custodian office sink	6:30:25 AM	3/13/25	16.0	5µg/l	X	EPA-200.8 REV.5.4
1	P-0-079-SF Faculty bathroom	6:31:22 AM	3/13/25	3.5	5µg/l		EPA-200.8 REV.5.4
26	P-0-080-SF Faculty bathroom handicap	6:31:53 AM	3/13/25	1.6	5µg/l		EPA-200.8 REV.5.4
14	P-0-081-SF Principal sink	6:33:13 AM	3/13/25	3.2	5µg/l		EPA-200.8 REV.5.4
12	P-0-082-SF Office hall bathroom	6:34:20 AM	3/13/25	1.6	5µg/l		EPA-200.8 REV.5.4
5	P-0-083-SF Office hall drinking fountain	6:35:05 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
2	P-0-084-SF Nurse office sink	6:36:54 AM	3/13/25	13.3	5µg/l	X	EPA-200.8 REV.5.4
3	P-0-085-SF Nurse bathroom sink	6:38:55 AM	3/13/25	ND	5µg/l		EPA-200.8 REV.5.4
10	P-0-086-SF Library sink	6:39:56 AM	3/13/25	5.3	5µg/l	X	EPA-200.8 REV.5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: March 27, 2025
Sample ID: 25007
Date Analyzed: 3/20/25
WO Number: 250313007

Customer: Greater Johnstown School District
Address: 1 Sir Bill Circle, Johnstown, New York 12095
Sample Location: Pleasant Avenue Elementary School
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes
Collection Date: 3/13/25
Collection Time: See Chart
Collected by: Angelo E. Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp: Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

**Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:*

- 1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).*
- 2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.*

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

<= Less than
>= Greater than
≈= Approximately
ND = Not Detected at reporting limit
NP = Not Provided
mg/l = milligrams per liter = ppm
ppm = parts per million
µg/l = micrograms per liter = ppb
ppb = parts per billion
gpg = grains per gallon
MCL = Maximum Contaminant Level
SM = Standard Methods For the
Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10709