

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: April 2, 2025
Sample ID: 25008
Date Analyzed: 3/28/25
WO Number: 252803008

Customer:	Greater Johnstown School District	Collection Date:	3/20/25
Address:	1 Sir Bills Circle, Suite 101, Johnstown, New York 12095	Collection Time:	See Chart
Sample Location:	Warren Street Elementary School	Collected by:	Angelo E. Finateri
Sample Point:	See Chart	Potable:	Yes
Water Source:	Municipal Water	Grab/Composite:	Grab
Chlorinated:	Yes	Receipt Temp:	

Sample #	Warren St., Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
185	W-0-003-SP Kitchen dish sprayer	4:51:44 AM	3/20/25	2.9	5.0		SM3113B
122	W-0-006-SP Kitchen two bay sprayer	4:50:07 AM	3/20/25	1.4	5.0		SM3113B
180	W-0-007-SF Kitchen two bay faucet	4:51:06 AM	3/20/25	1.2	5.0		SM3113B
174	W-0-008-SF Nurse bathroom sink	4:53:53 AM	3/20/25	1.2	5.0		SM3113B
123	W-0-009-SF Nurse office sink	4:54:33 AM	3/20/25	2.0	5.0		SM3113B
125	W-0-010-BF Office hall bottle filler	4:55:19 AM	3/20/25	ND	5.0		SM3113B
13	W-0-011-SF Room 1 sink	4:56:24 AM	3/20/25	3.4	5.0		SM3113B
11	W-0-012-BB Room 1 bubbler	4:56:54 AM	3/20/25	2.0	5.0		SM3113B
184	W-0-013-SF Room 2 sink	4:58:30 AM	3/20/25	4.9	5.0		SM3113B
183	W-0-014-BB Room 2 bubbler	4:59:06 AM	3/20/25	2.3	5.0		SM3113B
175	W-0-015-SF Room 3 sink	5:00:28 AM	3/20/25	3.7	5.0		SM3113B
NS	W-0-016-BB Room 3 bubbler	NS	NS	Not Sampled	5.0		SM3113B
176	W-0-017-SF Room 4 sink	5:03:14 AM	3/20/25	6.8	5.0	X	SM3113B
178	W-0-018-BB Room 4 bubbler	5:03:52 AM	3/20/25	4.7	5.0		SM3113B
187	W-0-019-SF Room 5 sink	5:06:17 AM	3/20/25	ND	5.0		SM3113B
188	W-0-020-BB Room 5 bubbler	5:05:45 AM	3/20/25	ND	5.0		SM3113B
177	W-0-021-SF Room 6 sink	5:07:26 AM	3/20/25	1.7	5.0		SM3113B
172	W-0-0-22-BB Room 6 bubbler	5:07:45 AM	3/20/25	ND	5.0		SM3113B
9	W-0-023-SF Room 7 sink	5:10:44 AM	3/20/25	1.2	5.0		SM3113B
7	W-0-024-BB Room 7 bubbler	5:10:18 AM	3/20/25	1.7	5.0		SM3113B
173	W-0-025-SF Room 8 sink	5:12:37 AM	3/20/25	1.4	5.0		SM3113B
181	W-0-026-BB Room 8 bubbler	5:12:06 AM	3/20/25	2.1	5.0		SM3113B
							SM3113B
							SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: April 2, 2025
Sample ID: 25008
Date Analyzed: 3/28/25
WO Number: 252803008

Customer:	Greater Johnstown School District	Collection Date: 3/20/25
Address:	1 Sir Bills Circle, Suite 101, Johnstown, New York 12095	Collection Time: See Chart
Sample Location:	Warren Street Elementary School	Collected by: Angelo E. Finateri
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp:

Sample #	Warren St., Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifiers	Method
179	W-0-027-DF Girls locker fountain	5:13:58 AM	3/20/25	ND	5.0		SM3113B
186	W-0-033-SF Room 12 sink	5:15:24 AM	3/20/25	ND	5.0		SM3113B
189	W-0-034-BB Room 12 bubbler	5:16:10 AM	3/20/25	ND	5.0		SM3113B
170	W-0-035-SF Room 13 sink	5:17:20 AM	3/20/25	5.0	5.0		SM3113B
182	W-0036-BB Room 13 bubbler	5:17:40 AM	3/20/25	4.8	5.0		SM3113B
171	W-0-037-SF Room 14 sink	5:20:40 AM	3/20/25	3.1	5.0		SM3113B
169	W-0-038-BB Room 14 bubbler	5:21:03 AM	3/20/25	2.0	5.0		SM3113B
159	W-0-039-SF Office hall restroom sink	5:22:29 AM	3/20/25	3.7	5.0		SM3113B
164	W-0-041-SF Faculty hall restroom sink	5:23:35 AM	3/20/25	1.5	5.0		SM3113B
161	W-0-043-DF faculty hall drinking fountain	5:24:41 AM	3/20/25	ND	5.0		SM3113B
158	W-0-044-SF Faculty room sink	5:25:51 AM	3/20/25	ND	5.0		SM3113B
157	W-0-049-SF Room 18 sink	5:27:45 AM	3/20/25	2.0	5.0		SM3113B
165	W-0-050-SF Room 19 sink	5:29:16 AM	3/20/25	ND	5.0		SM3113B
156	W-0-051-BB Room 19 bubbler	5:28:58 AM	1/0/00	11.1	5.0	X	SM3113B
163	W-0-052-SF Room 20 sink	5:31:59 AM	3/20/25	1.0	5.0		SM3113B
160	W-0-053-BB Room 20 bubbler	5:31:18 AM	3/20/25	1.4	5.0		SM3113B
162	W-0-058-SF Chorus Room sink	5:33:54 AM	3/20/25	ND	5.0		SM3113B
155	W-0-059-DF Gym hall fountain	5:36:24 AM	3/20/25	ND	5.0		SM3113B
166	W-0-061-SS Room 10 sink	5:37:27 AM	3/20/25	ND	5.0		SM3113B
168	W-0-065-SF Gym hall handicap bath sink	5:37:30 AM	3/20/25	1.2	5.0		SM3113B
145	W-0-069-DF Boys locker fountain	5:38:59 AM	3/20/25	ND	5.0		SM3113B
142	W-0-070-SF Boys locker sink	5:40:00 AM	3/20/25	ND	5.0		SM3113B
							SM3113B
							SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: April 2, 2025
Sample ID: 25008
Date Analyzed: 3/28/25
WO Number: 252803008

Customer:	Greater Johnstown School District	Collection Date: 3/20/25
Address:	1 Sir Bills Circle, Suite 101, Johnstown, New York 12095	Collection Time: See Chart
Sample Location:	Warren Street Elementary School	Collected by: Angelo E. Finateri
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp:

Sample #	<u>Warren St., Elementary School Sample Point</u>	<u>Collection Time</u>	<u>Date</u>	<u>Test Result</u> (µg/l)	<u>MCL</u> (µg/l)	<u>Qualifiers</u>	<u>Method</u>
167	W-0-075-SF Room 24 sink	5:41:05 AM	3/20/25	2.2	5.0		SM3113B
151	W-0-076-SF Room 25 sink	5:43:38 AM	3/20/25	ND	5.0		SM3113B
152	W-0-077-BB Room 25 bubbler	5:42:40 AM	3/20/25	5.5	5.0	X	SM3113B
150	W-0-078-SF Room 26 sink	5:46:23 AM	3/20/25	1.2	5.0		SM3113B
146	W-0-079-BB Room 26 bubbler	5:45:51 AM	3/20/25	1.2	5.0		SM3113B
143	W-0-080-SF Room 27 sink	5:48:54 AM	3/20/25	1.0	5.0		SM3113B
149	W-0-081-BB Room 27 bubbler	6:48:54 AM	3/21/25	1.2	5.0		SM3113B
141	W-0-082-SF Room 28 sink	5:50:29 AM	3/20/25	4.7	5.0		SM3113B
144	W-0-083-BB Room 28 bubbler	5:50:04 AM	3/20/25	6.8	5.0	X	SM3113B
137	W-0-084-SF Room 29 Sink	5:52:47 AM	3/20/25	3.5	5.0		SM3113B
147	W-0-085-BB Room 29 bubbler	5:53:26 AM	3/20/25	2.4	5.0		SM3113B
136	W-0-086-SF Room 30 sink	5:54:57 AM	3/20/25	4.4	5.0		SM3113B
135	W-0-087-BB Room 30 bubbler	5:55:26 AM	3/20/25	ND	5.0		SM3113B
138	W-0-088-SF Room 31 left sink	5:57:02 AM	3/20/25	3.7	5.0		SM3113B
134	W-0-089-SF Room 31 center sink	5:58:58 AM	3/20/25	11.3	5.0	X	SM3113B
131	W-0-090-SF Room 31 right sink	5:59:11 AM	3/20/25	1.6	5.0		SM3113B
130	W-0-091-SF Room 32 left sink	6:01:51 AM	3/20/25	6.3	5.0	X	SM3113B
133	W-0-092-SF Room 32 center sink	6:00:40 AM	3/20/25	3.4	5.0		SM3113B
148	W-0-093-SF Room 32 right sink	6:01:23 AM	3/20/25	4.7	5.0		SM3113B
139	W-0-095-SF Art room fountain	6:02:51 AM	3/20/25	ND	5.0		SM3113B
154	W-0-096-SF Art room sink left	6:03:40 AM	3/20/25	2.8	5.0		SM3113B
132	W-0-097-SF Art room sink right	6:04:34 AM	3/20/25	4.4	5.0		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: April 2, 2025
Sample ID: 25008
Date Analyzed: 3/28/25
WO Number: 252803008

Customer: Greater Johnstown School District
Address: 1 Sir Bills Circle, Suite 101, Johnstown, New York 12095
Sample Location: Warren Street Elementary School
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes

Collection Date: 3/20/25
Collection Time: See Chart
Collected by: Angelo E. Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp:

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

**Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:*

- 1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).*
- 2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.*

Qualifiers Key:

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

< = Less than
> = Greater than
≈ = Approximately
NP = Not Provided
mg/l = milligrams per liter = ppm
ppm = parts per million
µg/l = micrograms per liter = ppb
ppb = parts per billion
gpg = grains per gallon
MCL = Maximum Contaminant Level
SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350