

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
219 Noonan Road  
Ft. Johnson, New York 12070  
Phone/Fax: (518) 842-5171

Date: May 15, 2025  
Sample ID: 25018  
Date Analyzed: 5/12/25  
WO Number: 250424018

Customer:	Greater Johnstown School District	Collection Date: 4/24/25
Address:	1 Sir Bills Circle, Suite 101, Johnstown, New York 12095	Collection Time: See Chart
Sample Location:	Glebe Street School	Collected by: Angelo E. Finateri
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp: Ambient

Sample #	Glebe Street School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
190	G-0-003-BB Room 13 bubbler.	6:26:20 AM	4/24/25	5.0	5.0		EPA 200.8 REV 5.4
195	G-0-006-BB Room 14 bubbler	6:27:55 AM	4/24/25	6.4	5.0	X	EPA 200.8 REV 5.4
198	G-0-009-BB Room 15 bubbler	6:29:45 AM	4/24/25	3.9	5.0		EPA 200.8 REV 5.4
191	G-0-012-BB Room 16 bubbler	6:31:23 AM	4/24/25	4.3	5.0		EPA 200.8 REV 5.4
179	G-0-015-SF Nurse bathroom sink	6:16:02 AM	4/24/25	4.0	5.0		EPA 200.8 REV 5.4
170	G-0-017-BB Room 1 bubbler	6:17:39 AM	4/24/25	5.6	5.0	X	EPA 200.8 REV 5.4
160	G-0-024-BB Room 5 bubbler	6:19:40 AM	4/24/25	5.5	5.0	X	EPA 200.8 REV 5.4
197	G-0-026-BB Room 6 bubbler	6:21:28 AM	4/24/25	3.4	5.0		EPA 200.8 REV 5.4
196	G-0-027-SF Faculty room sink	6:23:21 AM	4/24/25	3.7	5.0		EPA 200.8 REV 5.4
150	G-0-033-DF Front hall high fountain	6:14:13 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
177	G-0-034-DF Front hall low fountain	6:13:10 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
178	G-0-035-BF Front hall bottle filler	6:13:47 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
176	G-0-038-DF Fountain in the gym	6:11:50 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
161	G-0-040-SF Center table sink	6:04:31 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
154	G-0-041-SF Left three bay faucet	6:03:01 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
****	G-0-042-SF Right three bay faucet	****	4/24/25	****	5.0		EPA 200.8 REV 5.4
153	G-0-043-SP Three bay sprayer	6:03:18 AM	4/24/25	ND	5.0		EPA 200.8 REV 5.4
209	G-0-047-DF Fountain outside of gym	6:06:02 AM	4/24/25	2.7	5.0		EPA 200.8 REV 5.4
****	G-0-049-BB Room 7 bubbler	****	4/24/25	****	5.0		EPA 200.8 REV 5.4
151	G-0-054-SF Room 9 stainless counter sink	6:07:36 AM	4/24/25	2.6	5.0		EPA 200.8 REV 5.4
152	G-0-058-BB Room 10 bubbler	6:09:07 AM	4/24/25	8.9	5.0	X	EPA 200.8 REV 5.4
****	G-0-061-BB Room 11 bubbler	****	4/24/25	****	5.0		EPA 200.8 REV 5.4
148	G-0-064-BB Room 12 bubbler	6:10:24 AM	4/24/25	4.7	5.0		EPA 200.8 REV 5.4

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
219 Noonan Road  
Ft. Johnson, New York 12070  
Phone/Fax: (518) 842-5171

Date: May 15, 2025  
Sample ID: 25018  
Date Analyzed: 5/12/25  
WO Number: 250424018

Customer: Greater Johnstown School District  
Address: 1 Sir Bills Circle, Suite 101, Johnstown, New York 12095  
Sample Location: Glebe Street School  
Sample Point: See Chart  
Water Source: Municipal Water  
Chlorinated: Yes

Collection Date: 4/24/25  
Collection Time: See Chart  
Collected by: Angelo E. Finateri  
Potable: Yes  
Grab/Composite: Grab  
Receipt Temp: Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

## Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

*\*Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:*

- 1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).*
- 2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.*

## Qualifiers Key:

<b>Qualifiers:</b>	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

## Legend:

< = Less than  
> = Greater than  
≈ = Approximately  
NP = Not Provided  
mg/l = milligrams per liter = ppm  
ppm = parts per million  
µg/l = micrograms per liter = ppb  
ppb = parts per billion  
gpg = grains per gallon  
MCL = Maximum Contaminant Level  
SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350