

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: November 5, 2025
Sample ID: 25038
Date Analyzed: 10/30/25
WO Number: 251016038

Customer: Greater Johnstown School District
Address: 1 Sir Bills Circle, Suite 101, Johnstown, New York 12095
Sample Location: See Chart
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes

Collection Date: 10/16/25
Collection Time: See Chart
Collected by: Angelo E. Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp: Ambient

Sample #	Glebe Street School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
6	G-0-006-BB Room 14 bubbler	6:33:20 AM	10/16/25	9.6	5.0	X	EPA 200.8 REV 5.4
4	G-0-017-BB Room 1 bubbler	6:36:46 AM	10/16/25	21.1	5.0	X	EPA 200.8 REV 5.4
2	G-0-024-BB Room 5 bubbler	6:39:00 AM	10/16/25	21.9	5.0	X	EPA 200.8 REV 5.4
1	G-0-049-BB Room 7 bubbler first draw	6:30:25 AM	10/16/25	3.5	5.0		EPA 200.8 REV 5.4
10	G-0-058-BB Room 10 bubbler	6:29:03 AM	10/16/25	12.7	5.0	X	EPA 200.8 REV 5.4
9	G-0-061-BB Room 11 bubbler first draw	6:27:42 AM	10/16/25	5.4	5.0	X	EPA 200.8 REV 5.4
Sample #	Knox Middle School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
3	K-0-007-BB Cafeteria white fountain left bubbler first draw	6:46:56 AM	10/16/25	4.2	5.0		EPA 200.8 REV 5.4
5	K-0-008-BB Cafeteria white fountain right bubbler first draw	6:46:13 AM	10/16/25	22.4	5.0	X	EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: November 5, 2025
Sample ID: 25038
Date Analyzed: 10/30/25
WO Number: 251016038

Customer:	Greater Johnstown School District	Collection Date:	10/16/25
Address:	1 Sir Bills Circle, Suite 101, Johnstown, New York 12095	Collection Time:	See Chart
Sample Location:	See Chart	Collected by:	Angelo E. Finateri
Sample Point:	See Chart	Potable:	Yes
Water Source:	Municipal Water	Grab/Composite:	Grab
Chlorinated:	Yes	Receipt Temp:	Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

**Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:*

- 1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).*
- 2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.*

Qualifiers Key:

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

< = Less than
> = Greater than
≈ = Approximately
NP = Not Provided
mg/l = milligrams per liter = ppm
ppm = parts per million
µg/l = micrograms per liter = ppb
ppb = parts per billion
gpg = grains per gallon
MCL = Maximum Contaminant Level
SM = Standard Methods For the
Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350